

MARKLEEVILLE WATER COMPANY

P.O. Box 131

Markleeville, CA. 96120

(530) 694-2924

Markleeville Water Company (MWC) Water Service Connection Policy

Purpose: To standardize Corporation members understanding for new or renewed connections to MWC.

Connection to MWC facilities shall only be at the discretion/authorization of MWC, and only after the Corporation member has been issued a receipt from MWC indicating all required fees to connect have been successfully paid.

The Corporation member shall excavate to locate the MWC Corporation valve, i.e. curb stop. The Corporation member assumes complete responsibility for all real and consequential damage(s) to MWC piping, and other facilities, including the loss of treated water from the MWC system while repairs are being made, or to any damaged portion of the MWC system caused by the Corporation member. The member is responsible for all costs incurred by MWC to execute repairs of MWC equipment damaged by the Corporation member or others under the Corporation member's direction.

MWC will make every attempt to determine/locate MWC underground facilities for the Corporation member. However, the sole responsibility lies with the Corporation member whom shall proceed with all due caution in and around the potential MWC underground facilities, to carefully find those facilities. Negligence is not an acceptable excuse.

The Corporation member shall install a 'member owned shut off valve' within 3 linear ft of the MWC Corporation stop/curb stop valve designated by MWC, and only that curb stop. The shut off valve shall be installed within the Corporation member's parcel, even if further than 3 feet from the curb stop.

If, due to circumstances beyond the Corporation member's control, the Corporation member cannot maintain the 3 linear feet requirement, the Corporation member shall review with MWC the closest location on the Corporation member's parcel that the member intends to install the shut off valve. This review with MWC shall be done prior to the Corporation member installing the shut off valve.

The Corporation member is required to install a brass/bronze shut off valve. **Stop & Waste valves are prohibited** due to the potential to create an illegal cross contamination to a source of contaminated water.

The type of pipe installed between the MWC Corporation/curb stop valve and the corporation member shut off valve shall be no less than schedule 40, steel, bronze, copper, PVC or Poly pipe. If PVC fittings are used, the fittings can be slip/glue fittings with threaded male adapters to the MWC curb stop. If Poly pipe is used, the proper metal barbed fittings for this type of pipe shall be used.

If a glycol filled fire suppression system is installed, the Corporation member shall install double back flow prevention valves between the Corporation member's connection and MWC. This backflow prevention system shall be 100% accessible to MWC.

The Corporation member shall install burial locating tape in the same ditch as the connection pipe between MWC and the member shut off valve. The burial locating tape shall be installed 12" above the top of the connection pipe.



Revised 7-25-18

MARKLEEVILLE WATER COMPANY

P.O. Box 131

Markleeville, CA. 96120

(530) 694-2924

Ditch shading/fill shall be fines materials, **sand**, within 8" above the connection pipe to MWC. Natural fill can be used above the fines material. The Corporation member should exercise caution to sift out rocks larger than 1-1/2" for fill above the fines materials.

The Corporation member is required to notify MWC, and allow for MWC's inspection, when the installation of the connecting pipe to MWC, and the member shut off valve, are completed.

Any leaks in the Corporation member's installation shall be remedied by the Corporation member before MWC will turn on water service to the Corporation member's parcel.

If at any time after the installation of the connection pipe and shut off valve to MWC, MWC finds a leak in the Corporation member's system, or unattended running water from the Corporation member's parcel, MWC maintains the right to shut off the Corporation member's water service off at the MWC curb stop until the issue is remedied to MWC's satisfaction.

ONLY MWC personnel are authorized to operate MWC facilities. Neither the Member or your plumber may not.

